


### Check for gas leaks.

#### NEVER SEARCH FOR A GAS LEAK WITH A NAKED FLAME.

Ensure that the on/off valve (after the regulator) is in the off position (See Diagram). Open both cylinder valve slightly and using a leak detecting fluid, check that all connections are free from leaks. If a leak is detected at any time, turn off the cylinder valves and rectify the leak.



### To light the beacon:

When lighting the beacon a large flame is produced, and so in the interests of safety the Bullfinch FirePower Torch Kit provided with the beacon should be used. Two people are required to light the beacon, one person to turn on the gas supply and the other to ignite the beacon.

### Lighting procedure:

#### Person 1.

- Assemble and light the blowtorch as per the instructions provided with the blowtorch, engage the ignition lock to provide a continuous flame. Holding the blowtorch by the lower edge of the gas cylinder, apply the flame to the lower edge of the beacon burner head.

#### Person 2.

- With the On/Off valve fully closed (see diagram) open both cylinder valves one full turn (this is so that in an emergency the valves can be shut off quickly).
- Once the ignition flame has been offered to the beacon, open the On/Off very slightly (to allow a small amount of gas to the burner), once the main burner has lit then the valve can be fully opened.

**Caution:** If the burner fails to ignite after 10 seconds turn off the gas supply, wait for 3 minutes and repeat lighting procedure.

**Caution:** Once the blowtorch has been used it should be put in a safe place away from any sources of ignition and allowed to cool down.

### To turn off the beacon:

Close the cylinder valves and allow the beacon flame to die away, then close the on/off valve.

Allow the beacon to cool down before dismantling.

Once dismantled, replace the protective covers in the gas cylinders and the 'Y' piece manifold, pigtail hose assembly and regulator.

# *Bullfinch*

## QUEEN'S BIRTHDAY BEACON

For propane only at 37 mbar

Heat input 48 kW

Gas consumption 3.5 kg/h

## H.M. Queen Elizabeth II 90<sup>th</sup> Birthday Celebration Beacon.

### No. 6290

## Assembly and lighting instructions.


### Important!

#### For Outdoor Use Only

#### Read these instructions before using the Beacon.

You will need 2 competent people to assemble and operate the beacon which must be attended at all times when lit.

You will need to supply one 47 Kg or two 19 kg cylinders of propane.  
**It is important to do a trial assembly and ignition procedure prior to the main event.**



The beacon is supplied complete with Gas hose and pressure regulator fitted and tested at the factory, also supplied is a 'Y' piece manifold and a Pigtail hose assembly enabling the Beacon to be connected to two cylinders of Propane. A regulator spanner and a bottle of leak detecting fluid plus a ground anchor and rope are also included. You will need to attach the burner head to the central tripod column (see Diagram). This joint is not part of the pressurized gas supply system and will not require any leak testing, but should be assembled spanner tight. A Bullfinch FirePower Torch Kit No. 364 comprising of a small cylinder of propane and a blowtorch is provided for igniting the beacon.

The beacon requires a flat area of 1320 mm diameter for erection plus space to place the propane gas cylinders, the tripod can be extended to a height of

Bullfinch (gas Equipment) Limited

Diadem Works, Kings Road, Tyseley, Birmingham B11 2AJ



Tel: +44 (0)121 765 2000 e-mail: sales@bullfinch-gas.co.uk web: www.bullfinch-gas.co.uk

2 metres to the lower edge of the burner head. The gas cylinders must stand upright and be secured to a suitable stable support.

### Safety Notes:

Read these notes before assembling and using the equipment.

- Ensure that a Dry Powder Type Fire Extinguisher is available at the beacon site.
- **Assemble and test the beacon prior to the main event to ensure that it functions correctly and is leak free.**
- Keep the burner head at least 3 metres away from any building, roof, wall or combustible material including trees and bushes and ensure that people are kept at least 5 metres away from the beacon.
- Gas cylinders should be at least 3 metres away from the Beacon.
- Check to ensure the gas connections are leak free, following the procedure detailed in the section "Check for Gas Leaks".
- In the event of a fire or emergency try to turn off the On/Off valve by the regulator first, then if possible turn off the cylinder valves. Remove the cylinders from the immediate fire and extinguish the fire with a dry powder fire extinguisher. If this is too dangerous call the fire brigade and evacuate the area.



### Assembly and setting up the Beacon:

On removal of the beacon from the packaging remove the red protective cover from the top of the tripod, then assemble the burner head as shown. Ensure that the joints in the area of the burner and tripod are tight, avoid using the burner head to tighten the assembly.

Uncoil the hose taking care not to drag the regulator across the ground. Slacken off the leg adjuster knob and spread the legs until the inner support legs are horizontal (this is the maximum footprint position), tighten the adjuster to ensure good stability. Slacken the column adjuster knob and adjust the tripod to the correct height, taking care to feed the gas hose through the lower central column to prevent damage to the hose from edge of the tripod. Do not raise the central column beyond the red band around the column, secure in position by tightening the column adjuster knob. If the beacon is to be used on hard ground it is advisable to use sand bags to weigh down the tripod to prevent it from being accidentally tipped over, position sand bags as shown in the diagram and identify area as a potential trip hazard. On soft ground it is recommended that you use the ground anchor provided then secure the beacon using webbing straps or suitable rope.

### Connection to the gas supply:

If one 47 kg gas cylinder is to be used the regulator can be fitted directly to the cylinder without using the 'Y' manifold or the Pigtail Hose assembly.

If using two gas cylinders ensure that both cylinder valves are in the off position (turned fully clockwise) then remove and keep the protective plugs from the gas cylinders (replace after use) and check that the sealing surface is free from any debris. Remove the protective cover from the 'Y' piece manifold, the pigtail hose assembly and the regulator (replace after use), check that the sealing surface is free from debris. Assemble the 'Y' piece manifold to one of the cylinder valves and one end of the pigtail hose assembly to the other cylinder valve. Secure the other end of the pigtail hose assembly to one outlet of the 'Y' piece manifold. The regulator should then be connected to the remaining outlet on the 'Y' manifold. Ensure that all the connections are spanner tight, the connections have left hand threads. Always ensure that trailing hose between the gas cylinders and the Beacon is allowed to run along the ground / floor to avoid a trip hazard.

